

LEGISLATIVE COUNCIL

C947

**QUESTION WITHOUT NOTICE
(Of which some notice has been given)**

Tuesday, 9 September 2014

Hon Robin Chapple to the Leader of the House representing the Minister for Energy.

With reference to the Pilbara Underground Power Project in Karratha (PUPP), I ask:

1. What was the dimension size of the trenches for the underground power in the original contracts let by Horizon Power?
 2. What was the dimension size of the eventual trenches?
 3. Why were the final trenches significantly larger?
 4. What were the fiscal implications for the project of the larger trenches?
-

I thank the Hon. Member for some notice of this question.

1. 500mm wide x 1300mm deep or 500mm wide x 1000mm deep depending on the type of cable.
2. The sizes varied. Without remeasuring it is not possible for Horizon Power to give an answer at this time.
3. See answer to question 2.
4. Nil.

M Mahon